


Contaminant Levels In the Outflow Water – mg/L

Hoard's Dairy



Series 1 = TKN Series 2 = Ammonia

- July 3, 2014 - "Dead Test" Commenced. Basin emptied and cleaned. (TKN level 31 mg/L & Ammonia 31mg/L)
- June 2015 - Concrete Repair Completed & Certified by REA Engineering.
- July 1, 2015 - Commence Second "Live Test ". Begin Refilling Basin. (TKN level 8.1 mg/L & Ammonia 9.9 mg/L)
- October 10, 2015 - Current Contaminant Level. (TKN level 1.2 mg/L & Ammonia .33 mg/L)
- December 02, 2105 – Anomaly Detected. Facility has begun compliance enforcement as sated in "Live Test Agreement" No additional waste and emptying of the waste storage structure.

Nitrogen, Kjeldahl 19 1.6 1.2 mg/L 12/09/15 08:00 12/09/15 11:20 2
Total Suspended Solids 110 9.1 2.9 mg/L 12/04/15 11:43 1
Ammonia 12 B 1.0 0.22 mg/L 12/07/15 19:10 12/07/15 22:25 5